DEPARTMENT OF HEALTH AND HUMAN SERVICES CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/18/2015 FORM APPROVED OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULT A. BUILDI	TIPLE CONSTRUCTION NG 01		(X3) DATE SURVEY COMPLETED	
		155363 B. WING			R 11/13/2015		
NAME OF PROVIDER OR SUPPLIER				STREET ADDRESS, CITY, STATE, ZIP CODE		1 11/	13/2013
WANTE OF FROMBER OR OUT FIELD					W WILLOW RD		
WILLOWDALE VILLAGE					ALE, IN 47523		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFI TAG	х	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	INITIAL COMMENTS		{K 0	00}			
	INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 09/30/15 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a). Survey Date: 11/13/15 Facility Number: 000254 Provider Number: 155363 AIM Number: 100266270 At this PSR survey, Willowdale Village was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. This one story facility was determined to be of Type V (000) construction and was fully sprinklered. The facility has a fire alarm system with hard wired smoke detectors in the corridors and spaces open to the corridors, plus battery operated smoke detectors in all resident sleeping rooms. The facility has a capacity of 50 and had a census of 40 at the time of this survey. All areas where the residents have customary access were sprinklered and all areas providing facility services were sprinklered except one detached wood framed garage and one detached wood framed shed, both used for facility storage.						
	Quality Review comp	eleted 11/17/15 - DA					
LABORATORY	DIRECTOR'S OR PROVIDER/	SUPPLIER REPRESENTATIVE'S SIGNATURE	=		TITLE		(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.